

130th MAINE LEGISLATURE

LD 129

LR 405(02)

Resolve, To Protect Consumers of Public Drinking Water by Establishing Maximum Contaminant Levels for Certain Substances and Contaminants

> Fiscal Note for Bill as Amended by Committee Amendment " " Committee: Health and Human Services Fiscal Note Required: Yes

Fiscal Note

State Mandate - Exempted

State MandatesUnit AffectedLocal CostRequired ActivityUnit AffectedSignificantRequires schools that are regulated as nontransient, noncommunity water systems
under the federal Safe Drinking Water Act: 1) to conduct initial monitoring for the
level of perfluoroalkyl and polyfluoroalkyl substances known as PFAS; 2) to
perform quarterly or annual monitoring if PFAS contaminants are above a certain
level, and 3) engage in mitigation if PFAS contaminants are in excess of the United
States Environmental Protection Agency health advisory level of 70 parts per
trillion.Unit Affected
SchoolSignificant
statewide

Pursuant to the Mandate Preamble, the two-thirds vote of all members elected to each House exempts the State from the constitutional requirement to fund 90% of the additional costs.

Fiscal Detail and Notes

According to data provided by the Department of Health and Human Services, Division of Environmental and Community Health, there are approximately 280 schools that are regulated as nontransient, noncommunity public water systems in the State. The department indicates that lab costs for analysis of a perfluoroalkyl and polyfluoroalkyl sample can range between \$150 and \$300. Also, the testing method (EPA 537.1) requires that a Quality Assurance field blank sample be analyzed with each PFAS sample, which may bring the total cost to an individual school to \$600 per test. If remediation is required, the cost to individual schools could range from \$10,000 to \$100,000 depending on the size of the school.

Any additional costs to the Department of Health and Human Services to adopt the changes in this bill are expected to be minor and can be absorbed within existing budgeted resources.